

Date Correction Plan Due 2/5/2025	NONCOMPLIANCE STATEMENT AND CORRECTION PLAN
TO FILE A COMPLAINT CALL 715-930-1148	

Use of Form: This form is used by certification / licensing staff to identify statute and / or administrative rule violation(s) and to outline imposed plans of correction, if applicable. This form is used by certified operators / licensed centers to meet the requirements of DCF 202.065, DCF 250.04(2)(i) and (3)(d), DCF 251.04(2)(L) and (3)(f), DCF 252.41(1)(L) and (2)(K). Failure to submit an appropriate correction plan by the due date listed above may result in sanctions identified in the statute and / or administrative rule. Public Schools may submit plans of correction however are not required to do so.

Instructions: The Noncompliance Statement below identifies the violation(s) of child care statute and / or administrative rule identified by the certification / licensing specialist. Complete the section labeled "Correction Plan" by indicating the steps that will be taken to address and correct each of the listed noncompliance(s). Identify expected completion date(s) for each item. Return the original to your certification / licensing specialist for approval and retain a copy. If this is a licensed child care, post your copy of the noncompliance statement and correction plan near the license in accordance with Wis. Stat. 48.657. This request for a correction plan is not an order imposing a sanction or penalty pursuant to Wis. Stat. 48.715. If the department decides to apply a statutory sanction and / or penalty for facts arising from this finding or a future finding, you will be given a notice of the sanction and / or penalty and your appeal rights.

Name - Certified Operator / Licensed Center Salem Lutheran Childcare And Preschool		Provider Number / Facility ID Number 7000578097 / 001 - 520460	
Address - Facility (Street, City, State, Zip Code) 1360 E La Salle Ave Barron WI 54812		Telephone Number 715-537-3011	
Rule/Statute Number Noncompliance Statement		Correction Plan	
1 251.06(4)(f) Electrical Outlet Limit Description: Contrary to rule, the center had more than two electrical appliances plugged into a wall outlet in the infant room.	Removed surge block from outlet allowing only the microwave + toaster plugged in. Moved other items. Spoke to all staff and let them know that appliances must be directly plugged in and not in any type of surge protector 1/13/2025		
Expected Completion Date		Verification Date	
1/13/2025			

NAME - Agency Worker
Wendy Badzinski, April Callihan
Date Issued
1/21/2025

SIGNATURE - Certified Operator or Designee / Licensee or Designee
Missie Frieburg
Date Signed
1/21/2025