

DEC 27 2024

<b>Date Correction Plan Due</b> 12/23/2024	<b>NONCOMPLIANCE STATEMENT AND CORRECTION PLAN</b>	SOUTHEASTERN REGIONAL OFFICE DCF DECE BEGR <b>TO FILE A COMPLAINT CALL</b> 262-446-7800
---	--	--

**Use of Form:** This form is used by certification / licensing staff to identify statute and / or administrative rule violation(s) and to outline imposed plans of correction, if applicable. This form is used by certified operators / licensed centers to meet the requirements of DCF 202.065, DCF 250.04(2)(i) and (3)(d), DCF 251.04(2)(L) and (3)(f), DCF 252.41(1)(L) and (2)(k). Failure to submit an appropriate correction plan by the due date listed above may result in sanctions identified in the statute and / or administrative rule. Public Schools may submit plans of correction however are not required to do so.

**Instructions:** The Noncompliance Statement below identifies the violation(s) of child care statute and / or administrative rule identified by the certification / licensing specialist. Complete the section labeled "Correction Plan" by indicating the steps that will be taken to address and correct each of the listed noncompliance(s). Identify expected completion date(s) for each item. Return the original to your certification / licensing specialist for approval and retain a copy. If this is a licensed child care, post your copy of the noncompliance statement and correction plan near the license in accordance with Wis. Stat. 48.657. This request for a correction plan is not an order imposing a sanction or penalty pursuant to Wis. Stat. 48.715. If the department decides to apply a statutory sanction and / or penalty for facts arising from this finding or a future finding, you will be given a notice of the sanction and / or penalty and your appeal rights.

<b>Name - Certified Operator / Licensed Center</b> Gods Little Angels Day Care		<b>Provider Number / Facility ID Number</b> 7000570847 / 001 - 1003760		
<b>Address - Facility (Street, City, State, Zip Code)</b> 1925 W Highland Ave Milwaukee WI 53233		<b>Telephone Number</b> 414-342-1127	<b>Date - Regulation Visit</b> 12/4/2024	
	<b>Rule/Statute Number Noncompliance Statement</b>	<b>Correction Plan</b>	<b>Expected Completion Date</b>	<b>Verification Date</b>
1	250.05(3)(e)2. <b>Provider Training - Current Cpr Certificate</b>  Description: CPR certificate did not clarify if it was valid for 2 or more years. Certificate is expired if valid for only one year. Class was not listed in registry.	was done 2/4/2023  All of my registry don't clarify for two, and she did not report to registry am not due until 2/25 will call children for class	2/4/2025	
2	250.06(2)(n)1.a. <b>Radon - Testing</b>  Description: No radon test on file to prove completion	testing was done on 6/5/23. install on 6/9/23. He said he was going to send or report it to the state.	done already 6/5/23 6/9/23	

**NAME - Agency Worker**  
Jennifer Mischock

**Date Issued**  
12/9/2024

**SIGNATURE - Certified Operator or Designee / Licensee or Designee**

*Delores E. Casler*

**Date Signed**

12-18-24

RECEIVED  
STATE OF WISCONSIN

DEC 27 2024

SOUTHEASTERN REGIONAL OFFICE  
DOF DECE BECR



WISCONSIN  
REGISTRY

## Registered Training Attendance

Leticia Browley

Event 901743: CPR, AED and First Aid for Children, Infants and Adults

2/4/2023

4.50 Hours

Personal Copy



WISCONSIN  
REGISTRY



Event ID: 901743

Name: Delores C Andrews

Leticia Browley

CPR, AED and First Aid for Children, Infants and Adults

2/4/2023

4.50 Hours

Signed:

Trainer

Send this section to The Registry with application or renewal.

All CPR, AED does not expire two yrs.  
not due until or before 2/4/25

# Radon Inspection Report

**Test Location:**

Delores Andrews Gods Little Angels Daycare  
1925 W. Highland Ave.  
Milwaukee, WI 53233

**Test For:**

Delores Andrews Gods Little Angels Daycare  
1925 W. Highland Ave.  
Milwaukee, WI 53233

**Inspected By:**

Ken Naujock NRPP Certification 110593RT  
457 W Chestnut St  
Burlington, WI 53105  
262-227-4956

Bldg. Type: Residential Single Family

Type: Post-Mitigation

RECEIVED  
STATE OF WISCONSIN

DEC 27 2024

SOUTHEASTERN REGIONAL OFFICE  
DCF DECE BECR

## Test Result: Pass

**Overall Average:**

0.3 pCi/l

**EPA Average:**

0.4 pCi/l

**Test Device Details:**

Serial Number: 61451026  
Model Number: 1028  
Last Calibration: 04/14/2023  
Next Calibration: 04/14/2024  
Cal-Factors: 2.7  
Motion Error: No

**Test Site Condition:**

Condition: Clear and Dry  
Wind: West 6-10mph  
Mitigation Sys: Installed and Active

**Test Summary:**

<u>CRM Location:</u> Basement	<u>Start:</u> 06/10/2023 10:37 AM	<u>Stop:</u> 06/12/2023 10:37 AM	<u>Interval:</u> 1 hr	<u>Duration:</u> 48 hr
<u>Radon Concentration:</u>	<u>Min:</u> 0.0	<u>Max:</u> 1.5	<u>Average:</u> 0.3	<u>Measurement Units:</u> pCi/l

**Comments:**

---

**Radon Inspection Chart**

---

---

**Test Result: Pass**

**Test Location:** 1925 W. Highland Ave. Milwaukee, WI 53233

**Inspection Report Date:** 06/13/2023

---

## **Test Checklist**

- The location of the detector was selected so the detector was not to be disturbed during testing.
- The monitor was not placed in an area of high humidity such as: Kitchen, laundry room, cellar, spa room, garage, crawl space or sump area.
- The detector was not located near drafts caused by HVAC vents, windows and doors.
- The detector was not placed near areas of excessive heat, such as a fireplace or in direct sunlight.
- The detector was placed within the breathing zone of at least 20 inches to 6 feet above the floor and at least 1 foot below the ceiling if suspended.
- The detector was not placed within 1 foot of outside walls of the home or within 3 feet of any windows or doors to the exterior of the home.

**Test Result: Pass**

**Test Location:** 1925 W. Highland Ave. Milwaukee, WI 53233

**Inspection Report Date:** 06/13/2023

**Test Table**

<u>Date/Time</u>	<u>Radon(pCi/l)</u>	<u>Temp(F)</u>	<u>Pres(inHg)</u>	<u>Humidity(%)</u>	<u>Flags</u>
06/10/23 11:37 AM	0.4	-	-	-	-
06/10/23 12:37 PM	0.4	-	-	-	-
06/10/23 01:37 PM	0.0	-	-	-	-
06/10/23 02:37 PM	0.0	-	-	-	-
06/10/23 03:37 PM	0.0	-	-	-	-
06/10/23 04:37 PM	0.0	-	-	-	-
06/10/23 05:37 PM	0.7	-	-	-	-
06/10/23 06:37 PM	0.0	-	-	-	-
06/10/23 07:37 PM	0.7	-	-	-	-
06/10/23 08:37 PM	0.0	-	-	-	-
06/10/23 09:37 PM	0.0	-	-	-	-
06/10/23 10:37 PM	0.4	-	-	-	-
06/10/23 11:37 PM	0.0	-	-	-	-
06/11/23 12:37 AM	1.5	-	-	-	-
06/11/23 01:37 AM	0.4	-	-	-	-
06/11/23 02:37 AM	0.0	-	-	-	-
06/11/23 03:37 AM	0.4	-	-	-	-
06/11/23 04:37 AM	0.4	-	-	-	-
06/11/23 05:37 AM	0.4	-	-	-	-
06/11/23 06:37 AM	0.7	-	-	-	-
06/11/23 07:37 AM	0.0	-	-	-	-
06/11/23 08:37 AM	0.7	-	-	-	-
06/11/23 09:37 AM	0.4	-	-	-	-
06/11/23 10:37 AM	0.0	-	-	-	-
06/11/23 11:37 AM	0.4	-	-	-	-
06/11/23 12:37 PM	0.4	-	-	-	-
06/11/23 01:37 PM	0.4	-	-	-	-
06/11/23 02:37 PM	0.0	-	-	-	-
06/11/23 03:37 PM	1.1	-	-	-	-
06/11/23 04:37 PM	0.4	-	-	-	-
06/11/23 05:37 PM	0.7	-	-	-	-
06/11/23 06:37 PM	0.4	-	-	-	-
06/11/23 07:37 PM	0.4	-	-	-	-
06/11/23 08:37 PM	0.4	-	-	-	-
06/11/23 09:37 PM	0.7	-	-	-	-
06/11/23 10:37 PM	0.4	-	-	-	-
06/11/23 11:37 PM	0.0	-	-	-	-
06/12/23 12:37 AM	0.0	-	-	-	-
06/12/23 01:37 AM	0.4	-	-	-	-
06/12/23 02:37 AM	0.0	-	-	-	-
06/12/23 03:37 AM	0.0	-	-	-	-
06/12/23 04:37 AM	0.0	-	-	-	-
06/12/23 05:37 AM	0.7	-	-	-	-
06/12/23 06:37 AM	0.4	-	-	-	-

**Test Result: Pass**

**Test Location:** 1925 W. Highland Ave. Milwaukee, WI 53233

**Inspection Report Date:** 06/13/2023

---

### Test Table

---

<u>Date/Time</u>	<u>Radon(pCi/l)</u>	<u>Temp(F)</u>	<u>Pres(inHg)</u>	<u>Humidity(%)</u>	<u>Flags</u>
06/12/23 07:37 AM	0.4	-	-	-	-
06/12/23 08:37 AM	0.4	-	-	-	-
06/12/23 09:37 AM	0.7	-	-	-	-
06/12/23 10:37 AM	0.4	-	-	-	-

---

**Test Result: Pass**

**Test Location:** 1925 W. Highland Ave. Milwaukee, WI 53233

**Inspection Report Date:** 06/13/2023

---

## **Radon Test Information**

### **Radon Risk Information**

Radon causes lung cancer by means of the decay of its daughter products after breathing in air contaminated with higher levels of Radon. The World Health Organization (WHO) estimates that 15% of lung cancers worldwide are caused by exposure to elevated indoor levels of Radon. Overall, radon is the second leading cause of lung cancer responsible for about 21,000 lung cancer deaths every year in the US alone. Radon gas is the number one cause of lung cancer among non-smokers. The U.S. Environmental Protection Agency (EPA), the U.S. Surgeon General, and the Center for Disease Control and Prevention (CDC) strongly recommend that ALL homebuyers have an indoor radon test performed prior to purchase or taking occupancy and recommend having the radon levels professionally mitigated if elevated radon concentrations are found.

### **Understanding Radon Test Results**

Recommended Action Levels vary by country and typically range from 3 pCi/l (100 Bq/m<sup>3</sup>) to 8 pCi/l (300 Bq/m<sup>3</sup>). Recommendations below are based on test results by a Continuous Radon Monitor (CRM) Test of at least 24h duration and are based on recommendations by the EPA.

Measured Average Radon Level:

- At or above 4.0 pCi/l (148 Bq/m<sup>3</sup>): Corrective measures to reduce exposure to radon gas is strongly recommended (ANSI MAH2014)
- Between 2-4 pCi/l (74-148 Bq/m<sup>3</sup>): Consider mitigation or periodic retest as indoor Radon levels vary by season and weather conditions
- Below 2 pCi/l (74 Bq/m<sup>3</sup>): Consider bi-annual retest or whenever significant changes to the home structure or mechanical systems occurred

**Test Result: Pass**

**Test Location:** 1925 W. Highland Ave. Milwaukee, WI 53233

**Inspection Report Date:** 06/13/2023