DEPARTMENT OF CHILDREN AND FAMILIES
Division of Early Care and Education

STATE OF WISCONSIN

Date Correction Plan Due 11/12/2026	NONCOMPLIANCE STATEMENT AND CORRECTION PLAN	TO FILE A COMPLAINT CALL 715-930-1148

Use of Form: This form is used by certification / licensing staff to identify statute and / or administrative rule violation(s) and to outline imposed plans of correction, if applicable. This form is used by certified operators / licensed centers to meet the requirements of DCF 202.065, DCF 250.04(2)(i) and (3)(d), DCF 251.04(2)(L) and (3)(f)., DCF 252.41(1)(L) and (2)(k). Failure to submit an appropriate correction plan by the due date listed above may result in sanctions identified in the statute and / or administrative rule. Public Schools may submit plans of correction however are not required to do so.

Instructions: The Noncompliance Statement below identifies the violation(s) of child care statute and / or administrative rule identified by the certification / licensing specialist. Complete the section labeled "Correction Plan" by indicating the steps that will be taken to address and correct each of the listed noncompliance(s). Identify expected completion date(s) for each item. Return the original to your certification / licensing specialist for approval and retain a copy. If this is a licensed child care, post your copy of the noncompliance statement and correction plan near the license in accordance with Wis. Stat. 48.657. This request for a correction plan is not an order imposing a sanction or penalty pursuant to Wis. Stat. 48.715. If the department decides to apply a statutory sanction and / or penalty for facts arising from this finding or a future finding, you will be given a notice of the sanction and / or penalty and your appeal rights.

Name - Certified Operator / Licensed Center		Provider Number / Facility ID Number
Trinity Christian Preschool		0000578200 / 001 - 520180
Address - Facility (Street, City, State, Zip Code) 1314 E Lexington Blvd Eau Claire WI 547016434	**Telephone Number** 715-832-6601	**Date - Regulation Visit** 10/28/2026

	Rule/Statute Number Noncompliance Statement	Correction Plan	Expected Completion Date	Verification Date
1	251.06(4)(a) **Fire Extinguishers - Operable, Inspected, Labeled** Description: Rule states "Each fire extinguisher on the premises of a center shall be operable at all times, inspected once a year by a qualified person and bear a label indicating its present condition and date of the last inspection." Contrary to rule, three fire extinguishers on the premises, were previously inspected in February of 2025, making it over one year since the last inspection.	Maintenance staff member, Don Peterson contacted Summitt Fire Extinguishers on Wednesday, October 28, 2026 and placed a service request to check all fire extinguishers in our building. Completion date is stated by month end.	11/30/2026	

NAME - Agency Worker
Heather Ruf

Date Issued
10/28/2026

SIGNATURE - Certified Operator or Designee / Licensee or Designee
Kimberly Deweese

Date Signed
11/4/2026