

P 1 / 4
6088459947
Mar. 05. 2024 05:15 PM Kings Kids Academy

Date Correction Plan Due 3/18/2024	NONCOMPLIANCE STATEMENT AND CORRECTION PLAN	TO FILE A COMPLAINT CALL 608-422-6765
--	--	---

Use of Form: This form is used by certification / licensing staff to identify statute and / or administrative rule violation(s) and to outline imposed plans of correction, if applicable. This form is used by certified operators / licensed centers to meet the requirements of DCF 202.065, DCF 250.04(2)(i) and (3)(d), DCF 251.04(2)(L) and (3)(f), DCF 252.41(1)(L) and (2)(k). Failure to submit an appropriate correction plan by the due date listed above may result in sanctions identified in the statute and / or administrative rule. Public Schools may submit plans of correction however are not required to do so.

Instructions: The Noncompliance Statement below identifies the violation(s) of child care statute and / or administrative rule identified by the certification / licensing specialist. Complete the section labeled "Correction Plan" by indicating the steps that will be taken to address and correct each of the listed noncompliance(s). Identify expected completion date(s) for each item. Return the original to your certification / licensing specialist for approval and retain a copy. If this is a licensed child care, post your copy of the noncompliance statement and correction plan near the license in accordance with Wis. Stat. 48.657. This request for a correction plan is not an order imposing a sanction or penalty pursuant to Wis. Stat. 48.715. If the department decides to apply a statutory sanction and / or penalty for facts arising from this finding or a future finding, you will be given a notice of the sanction and / or penalty and your appeal rights.

Name - Certified Operator / Licensed Center King's Kids Academy		Provider Number / Facility ID Number 4000587594 / 001 - 2001067	
Address - Facility (Street, City, State, Zip Code) 8133 Mansion Hill Ave Madison WI 537194489		Telephone Number 608-845-5464	Date - Regulation Visit 3/1/2024
	Rule/Statute Number Noncompliance Statement	Correction Plan	Expected Completion Date Verification Date
1	251.06(10)(h) Toilets & Sinks - Water Temperature Description: The water in the Twos and Junior K classroom sinks exceeded the maximum allowed temperature for water accessible to children.	The temperature on the water heater reduced to 125°F	3/4/2024
2	251.06(2)(d) Access To Materials Potentially Harmful To Children Description: Potentially harmful materials were accessible to children when Lysol spray and cleaning supplies were under a sink that was not locked. In addition, two classrooms had scissors, a stapler, and super glue in drawers that were not locked. Repeat violation: Previously cited on 3/23/2022	Install latches on each drawer and Cabinet	3/6/2024

Name - Certified Operator / Licensed Center King's Kids Academy		Provider Number / Facility ID Number 4000587594 / 001 - 2001067		
Address - Facility (Street, City, State, Zip Code) 8133 Mansion Hill Ave Madison WI 537194489		Telephone Number 608-845-5464	Date - Regulation Visit 3/1/2024	
	Rule/Statute Number Noncompliance Statement	Correction Plan	Expected Completion Date	Verification Date
3	251.06(4)(f) Electrical Outlet Limit Description: Three electrical appliances were plugged into an outlet in the Twos classroom.	Move items in the room so they can each be plugged into individual outlets	3/5/2024	

NAME - Agency Worker
Casey Allison

Date Issued
3/4/2024

SIGNATURE - Certified Operator or Designee / Licensee or Designee

Date Signed

Kari M. Enger

3/5/2024