

Date Correction Plan Due 12/26/2025	NONCOMPLIANCE STATEMENT AND CORRECTION PLAN	TO FILE A COMPLAINT CALL 715-361-7700
---	--	---

Use of Form: This form is used by certification / licensing staff to identify statute and / or administrative rule violation(s) and to outline imposed plans of correction, if applicable. This form is used by certified operators / licensed centers to meet the requirements of DCF 202.065, DCF 250.04(2)(f) and (3)(d), DCF 251.04(2)(L) and (3)(f), DCF 252.41(1)(L) and (2)(k). Failure to submit an appropriate correction plan by the due date listed above may result in sanctions identified in the statute and / or administrative rule. Public Schools may submit plans of correction however are not required to do so.

Instructions: The Noncompliance Statement below identifies the violation(s) of child care statute and / or administrative rule identified by the certification / licensing specialist. Complete the section labeled "Correction Plan" by indicating the steps that will be taken to address and correct each of the listed noncompliance(s). Identify expected completion date(s) for each item. Return the original to your certification / licensing specialist for approval and retain a copy. If this is a licensed child care, post your copy of the noncompliance statement and correction plan near the license in accordance with Wis. Stat. 48.657. This request for a correction plan is not an order imposing a sanction or penalty pursuant to Wis. Stat. 48.715. If the department decides to apply a statutory sanction and / or penalty for facts arising from this finding or a future finding, you will be given a notice of the sanction and / or penalty and your appeal rights.

Name - Certified Operator / Licensed Center Family Development Center		Provider Number / Facility ID Number 5000569345 / 004 - 620280	
Address - Facility (Street, City, State, Zip Code) 1640 W River Dr Stevens Point WI 544813430		Telephone Number 715-343-7153	Date - Regulation Visit 12/3/2025
Rule/Statute Number	Correction Plan	Expected Completion Date	Verification Date
1 251.06(4)(d) Exits & Passageways - Unobstructed, Minimum Width Description: The lit fire exit in Classroom 2 did not have a clear passage with a width of three feet and was partially obstructed by shelving.	The shelf had moved during play and was moved back. Teaching staff will be monitoring this throughout the day.	12/3/25	

NAME - Agency Worker
Heather Struck

Date Issued
12/10/2025

SIGNATURE - Certified Operator or Designee / Licensee or Designee

Date Signed

Samantha Zimmerman

12/11/25