

Date Correction Plan Due
4/19/2023

**NONCOMPLIANCE STATEMENT AND CORRECTION
PLAN**

TO FILE A COMPLAINT CALL
608-422-6765

Use of Form: This form is used by certification / licensing staff to identify statute and / or administrative rule violation(s) and to outline imposed plans of correction, if applicable. This form is used by certified operators / licensed centers to meet the requirements of DCF 202.065, DCF 250.04(2)(i) and (3)(d), DCF 251.04(2)(L) and (3)(f), DCF 252.41(1)(L) and (2)(k). Failure to submit an appropriate correction plan by the due date listed above may result in sanctions identified in the statute and / or administrative rule. Public Schools may submit plans of correction however are not required to do so.

Instructions: The Noncompliance Statement below identifies the violation(s) of child care statute and / or administrative rule identified by the certification / licensing specialist. Complete the section labeled "Correction Plan" by indicating the steps that will be taken to address and correct each of the listed noncompliance(s). Identify expected completion date(s) for each item. Return the original to your certification / licensing specialist for approval and retain a copy. If this is a licensed child care, post your copy of the noncompliance statement and correction plan near the license in accordance with Wis. Stat. 48.715. If the department decides to apply a statutory sanction and / or penalty for facts arising from this finding or a future finding, you will be given a penalty pursuant to Wis. Stat. 48.715. This request for a correction plan is not an order imposing a sanction or notice of the sanction and / or penalty and your appeal rights.

Name - Certified Operator / Licensed Center

Tender Heart Childcare

Provider Number / Facility ID Number

4000578294 / 003 - 1014968

Address - Facility (Street, City, State, Zip Code)
N1350 State Road 113 Lodi WI 535559612

Telephone Number
608-669-1862

Date - Regulation Visit
4/3/2023

1	Rule/Statute Number Noncompliance Statement	Correction Plan	Expected Completion Date	Verification Date
	250.06(2)(L)1. Carbon Monoxide - One Or Two Family Residence Description: The center did not have a carbon monoxide detector installed on each floor level when the first floor of the residence did not have one installed.	Install one	4-15-23	

ME - Agency Worker
/ Anderson

ATURE - Certified Operator or Designee / Licensee or Designee
Jennifer Burke

CFS0294-E (R 06/2011)

Date Issued
4/5/2023

Date Signed

4-15-23