

Date Correction Plan Due 1/18/2024	NONCOMPLIANCE STATEMENT AND CORRECTION PLAN	TO FILE A COMPLAINT CALL 715-930-1148
--	--	---

Use of Form: This form is used by certification / licensing staff to identify statute and / or administrative rule violation(s) and to outline imposed plans of correction, if applicable. This form is used by certified operators / licensed centers to meet the requirements of DCF 202.065, DCF 260.04(2)(i) and (3)(d), DCF 261.04(2)(L) and (3)(f), DCF 262.41(1)(L) and (2)(k). Failure to submit an appropriate correction plan by the due date listed above may result in sanctions identified in the statute and / or administrative rule. Public Schools may submit plans of correction however are not required to do so.

Instructions: The Noncompliance Statement below identifies the violation(s) of child care statute and / or administrative rule identified by the certification / licensing specialist. Complete the section labeled "Correction Plan" by indicating the steps that will be taken to address and correct each of the listed noncompliance(s). Identify expected completion date(s) for each item. Return the original to your certification / licensing specialist for approval and retain a copy. If this is a licensed child care, post your copy of the noncompliance statement and correction plan near the license in accordance with Wis. Stat. 48.657. This request for a correction plan is not an order imposing a sanction or penalty pursuant to Wis. Stat. 48.715. If the department decides to apply a statutory sanction and / or penalty for facts arising from this finding or a future finding, you will be given a notice of the sanction and / or penalty and your appeal rights.

Name - Certified Operator / Licensed Center Leaps And Bounds Child Care		Provider Number / Facility ID Number 8000587118 / 001 - 2000367	
Address - Facility (Street, City, State, Zip Code) 31857 Fremont Ave Tomah WI 546606571		Telephone Number 608-372-6828	Date - Regulation Visit 12/14/2023
Rule/Statute Number Noncompliance Statement	Correction Plan	Expected Completion Date	Verification Date
251.06(4)(d) Exits & Passageways - Unobstructed, Minimum Width Description: Each exit did not have a minimum unobstructed, clear width of at least 3 feet. On the day of the monitoring visit, the infant room doorway had a safety gate installed which reduced the clear width to less than 3 feet.	<i>Infant safety gate was removed and door will remain closed.</i>	<i>12/14/23</i>	

AME - Agency Worker
Jennifer Stubbe

Date Issued:
1/4/2024

SIGNATURE - Certified Operator or Designee / Licensee or Designee

Date Signed

Sara Long

01/09/24